

LIST OF DIFFERENCES

17.4 SSTS STANDARDS

A. STANDARDS ADOPTED BY REFERENCE

The County hereby adopts by reference Minnesota Rules, Chapters 7080 and 7081 in their entirety as now constituted and from time to time as amended. This adoption does not supersede the County's right or ability to adopt local standards that are in compliance with Minnesota Statute, Section 115.55.

B. AMENDMENTS TO THE ADOPTED STANDARDS

1. List of Adopted Standards

- a. Type V Systems will not be allowed.
- b. Three (3) feet of vertical separation shall be required for all Type I, II, III & IV Systems.
- c. Systems receiving a Notice of Non-Compliance (NONC) shall be updated within one (1) year of NONC.
- d. Systems deemed an Imminent Threat to Public Health (ITPH) shall be updated within six (6) months.
- e. Septic designs must be submitted to the Department within twenty (20) calendar days after receipt of NONC or ITPH.
- f. Request to the Department for a septic inspection or soil verification must be received one (1) calendar day prior to the inspection.
- g. Record drawings must be submitted to the Department within five (5) calendar days.
- h. Property transfers with a NONC must be updated within one (1) year of notice of NONC.
- i. If compliance inspections cannot be performed from November 1 – April 30 due to soil conditions and/or weather conditions for property transfers and/or permit requirements, the compliance inspection is required to be submitted to the Department by the following June 1 and the applicant shall submit a certificate of compliance by the following September 30. Permits and/or variances may be issued by the County during this period.

- j. Filing the Compliance Inspection after a property transfer shall be the responsibility of the landowner.
- k. In all non-shoreland Districts, any zoning permits requested for the principle structure shall require a compliance inspection.
- l. In all shoreland Districts, any zoning permits requested shall require a compliance inspection.
- m. A fifty (50) foot setback is required from the top of the drainage ditch or waters of the state, unless otherwise designated.
- n. A seventy-five (75) foot setback from Type 3 through 8 wetlands.
- o. A ten (10) foot setback from a pool.
- p. No SSTS shall be constructed within thirty (30) feet from the top or the toe of a bluff.
- q. Continued use of an existing treatment tank shall be exempt from the required setback to a building as described in 17.4.D.1.a, providing the tank meets the requirements of 17.5.D.2.b of this Section and shall not be located under or within a structure or other impermeable surface.